Cleanroom Inspection Checklist

Use this checklist to go through your cleanroom inspecting room cleanliness, facility integrity and compliance.

Inspect for cleanliness, note any visible gross contamination such as dust, debris, or staining

☐	Tops of doors and door closers
☐	Door gaskets/seals
☐	Window sills/frames and door frames
☐	Tops of equipment
☐	Equipment door and access panel gaskets/seals
☐	Condensate lines/pans for refrigeration units
☐	Service lines and piping (example: air and gas lines, supply piping, power cords, etc.)
☐	Return air grills and registers (ceiling and wall as applicable)
☐	Flooring
☐	Cart wheels

Inspect for integrity, note any compromised seals or damaged surfaces

☐	Wall joints
☐	Wall panels
☐	Access panels
☐	Wall protrusions (example: utility drops, fire alarms, electrical receptacles)
☐	Wall to ceiling join
☐	Ceiling panels
☐	Light fixtures
☐	HEPA enclosures
☐	Floor to wall joint
☐	Flooring

Inspect for compliance

☐	Items not stored on floor
☐	Items, equipment, and fixtures not blocking air returns
☐	Door interlocks functional
☐	Surfaces free of residue

Copyright © 2025 Contec, Inc. All rights reserved.

Contec, Inc.
Spartanburg, SC 29303 USA
tel: +1-864-503-8333
cleanroom.contecinc.com

Customer Service
tel: 1-866-855-4682
cs_cleanroom@contecinc.com

CONTEC® CLEANROOM